

File E186249  
Project 06CA39933

September 5, 2006

REPORT

On

COMPONENT - POWER SUPPLIES, INFORMATION TECHNOLOGY EQUIPMENT

Astec International Limited Philippines Branch  
Quezon City 1110, Philippines

Copyright © 2006 Underwriters Laboratories Inc.

Underwriters Laboratories Inc. authorises the above-named company to reproduce this Report provided it is reproduced in its entirety.

Underwriters Laboratories Inc. authorises the above-named company to reproduce the latest pages of that portion of this Report consisting of this Cover Page through Page 2.

## DESCRIPTION

## PRODUCT COVERED:

USR, CNR Component - Switching Power Supply, Models DS850-9 and DS650-9 for use in Information Technology Equipment.

## ELECTRICAL RATINGS:

MODEL	INPUT	OUTPUT	
DS850-9	100 - 240 V AC 12 A 50 / 60 Hz	+ 3.3 V aux + 48 V dc	6 A max 17.5 A max

Maximum Combined Output Power is 850 W.

DS650-9	100 - 240 V AC 10 A 50 / 60 Hz	+ 3.3 V aux + 48 V dc	6 A max 13.3 A max
---------	--------------------------------------	--------------------------	-----------------------

Maximum Combined Output Power is 650 W.

## TECHNICAL CONSIDERATIONS (NOT FOR FIELD REPRESENTATIVE USE):

General - The units are for use in product where the acceptability of the combination is determined by Underwriters Laboratories Inc.

\*Both USR and CNR indicate investigation to the Standard for Safety of Information Technology Equipment, **UL 60950-1, 2nd Edition, 2014-10-14/CSA C22.2 No. 60950-1-07, 2nd Edition, 2014-10.**

Conditions of Acceptability - When installed in the end-use equipment, the following are the considerations to be made:

1. \*These components have been judged on the basis of the required creepages and clearances in the Second Edition of the Standard for Safety of Information Technology Equipment, **UL 60950-1, 2nd Edition, 2014-10-14/CSA C22.2 No. 60950-1-07, 2nd Edition, 2014-10**, Sub-clause 2.10 and Annex G (altitude requirement), which covers the end-use product for which the components were designed. The functional insulation has been evaluated by conducting Component Failure Test per Sub-clause 5.3.4(c) of **UL 60950-1, 2nd Edition, 2014-10-14/CSA C22.2 No. 60950-1-07, 2nd Edition, 2014-10.**
2. These power supplies have only been evaluated for use in a pollution degree 2 environment.

3. \*These power supplies were evaluated with the assumption that the power source is a TN power system as defined by **UL 60950-1, 2nd Edition, 2014-10-14/CSA C22.2 No. 60950-1-07, 2nd Edition, 2014-10.**
4. A suitable fire, mechanical and electrical enclosure shall be provided by end use equipment.
5. \*These power supplies have been evaluated for use in Class I equipment as defined in **UL 60950-1, 2nd Edition, 2014-10-14/CSA C22.2 No. 60950-1-07, 2nd Edition, 2014-10** and shall be properly earthed or bonded to earth in the end-use. An additional evaluation shall be made if the power supplies are intended for use in other than Class I equipment.
6. +48 V output of the power supply is unearthed energy hazard SELV, while + 3.3 Vaux is unearthed non-energy hazard SELV. Sub-clause 2.2.3.1 per \* **UL 60950-1, 2nd Edition, 2014-10-14/CSA C22.2 No. 60950-1-07, 2nd Edition, 2014-10** were used to maintain the insulation of SELV from primary circuits.
7. These power supplies have been evaluated for use in 25°C and 50°C ambient.
8. Transformers T103, T104, T131, T107 and T402 employ Class F electrical insulation system.
9. The secondary output connector has not been evaluated for field connections.
10. \*These power supplies are classified Level 5 as defined by **UL 60950-1, 2nd Edition, 2014-10-14/CSA C22.2 No. 60950-1-07, 2nd Edition, 2014-10.**
11. \*These power supplies can be operated in an elevation of maximum 3100 meters above sea level. Annex G of **UL 60950-1, 2nd Edition, 2014-10-14/CSA C22.2 No. 60950-1-07, 2nd Edition, 2014-10** was used in determining the clearance requirement.
12. Result for discharge of capacitor for L-N and N-PE at T=1 second is 6V, further consideration should be considered in end use.