



Ref. Certif. No.

SG-LE-00871M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC**CB TEST CERTIFICATE
CERTIFICAT D'ESSAI OC**Product
ProduitSwitch mode power supplies
(Switch Mode LED Driver for Built-in)Name and address of the applicant
Nom et adresse du demandeurAstec International Limited - Philippine Branch
3rd & 4th Floor, Techno Plaza One Bldg, #18 Orchard Road, Eastwood
City Cyberpark, Bagumbayan
1110 Quezon City, PHILIPPINESName and address of the manufacturer
Nom et adresse du fabricantAstec International Limited - Philippine Branch, 3rd & 4th Floor, Techno
Plaza One Bldg, #18 Orchard Road, Eastwood City Cyberpark,
Bagumbayan, 1110 Quezon City, PHILIPPINESName and address of the factory
Nom et adresse de l'usineAstec Power Philippines Inc., 104 Laguna Boulevard, Laguna Technopark,
4026 Sta. Rosa Laguna, PHILIPPINESRatings and principal characteristics
Valeurs nominales et caractéristiques principales

Rated Input :	100-240VAC (For LDS100-24) 100-277VAC (For LDS100-24-H, LDS100-30-H, LDS100-31-H and LDS100-48-H) 50/60Hz, 1.5A
Rated Output :	See test report for details
Degree of Protection :	IPX0
Method of Installation:	Built-in
Protection against Electric Shock :	SELV-equivalent
Type of Output :	Constant current type
tc :	90°C

Model/type Ref.
Ref. de typeLDS100-24, LDS100-24-H, LDS100-30-H,
LDS100-31-H, LDS100-48-HAdditional information (if necessary)
Information complémentaire (si nécessaire)Certificate SG-LE-00871 issued 2014-04-16 is replaced by this version due
to technical changes. See Test Report for National Differences and Group
Differences.A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à laIEC 61347-1/A2:2012
IEC 61347-2-13:2006as shown in the Test Report Ref. No.
which forms part of this certificate
comme indiqué dans le Rapport d'essais numéro
de référence qui constitue une partie de ce
certificatTÜV SÜD PSB Pte Ltd
211-400556-100This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**Date, 2014-09-04
CBS 14 07 51485 01357
(Kenneth Lau)

TÜV SÜD PSB Pte Ltd · 1 Science Park Drive · Singapore 118221

PSB Singapore